



BERKELEY FIRE DEPARTMENT
 2100 MARTIN LUTHER KING JR. WAY, 2ND FL
 BERKELEY, CA. 94704
 (510) 981-5585

FIRE PREVENTION INSPECTION REPORT WILDLAND-URBAN INTERFACE AREA

Occupancy Address	Business Name	<input type="checkbox"/> NO VIOLATIONS NOTED
Type of Business	Occupancy Group A B E F H I M R1 R2 R3 S U	APN (Parcel) #
Property Owner	Property Owner's Address	Phone #
Type of Inspection <input type="checkbox"/> Vegetation (Annual Hazardous Fire Area) <input type="checkbox"/> Vegetation (Re-inspection) <input type="checkbox"/> Citizen Complaint		<input type="checkbox"/> 1 st Notice <input type="checkbox"/> 2 nd Notice <input type="checkbox"/> Refer to F. P.

NOTICE OF FIRE AND SAFETY HAZARDS

You are hereby notified that an inspection of your premises for the minimum fire & life safety requirements of Berkeley Municipal Code Chapter 19.48, known as "Berkeley Fire Code" (BFC) and/or the provisions of the California Fire Code (CFC), has revealed the following violations.

<p>Fire Code Violation</p> <p><input type="checkbox"/> A CFC 304.1 Waste Accumulation Prohibited Prohibited in buildings, structures or upon premises</p> <p><input type="checkbox"/> B CFC 503.4 Obstruction of Fire Apparatus Access Road Obstruction of width or height prohibited. Min. 13'-6" vertical clearance and 26' width required.</p> <p><input type="checkbox"/> C CFC 505.1 Address Identification Must be plainly legible from street / road frontage - min. 4 inches high on contrasting background.</p> <p><input type="checkbox"/> D BFC 4906.5.2 Trimming Clearance (Electrical Conductor) min. 4' clearance from high voltage conductor (>400V)</p> <p><input type="checkbox"/> E BFC 4906.5.3 Trimming Clearance (Electrical Power Line) min. 6" clear from high voltage (>750V)</p> <p><input type="checkbox"/> F BFC 4906.6 Clearance of Brush and Vegetation from Roadways Clear within 10 feet on each side of highways, streets and roads. Single plant specimens and ground covers permissible provided they will not readily transmit fire.</p> <p><input type="checkbox"/> G BFC 4908.5 Spark Arresters. (2019 CBC 2113.9.2) Provide chimneys, barbecues, incinerators or heating appliances using solid/liquid fuels with a spark arrester.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>Recommended Separation of Plants Based on Slope: 0-20% slope= 2x fuel height (Shrubs) or 10Ft (Trees) 20-40% slope= 4x fuel height (Shrubs) or 20Ft (Trees) >40% slope= 6x fuel height (Shrubs) or 30Ft (Trees)</p> </div>	<p>Fire Code Violation</p> <p><input type="checkbox"/> H BFC 4907.2 Clearance of Brush and Vegetative Growth from Structures. May include but is not limited to: Create 30' defensible space around structure-</p> <ul style="list-style-type: none"> <input type="checkbox"/> 1. cut grass and flammable vegetation to ≤3 inches, remove if mulch is >5" deep [single plant specimens ok if they will not rapidly transmit fire to a structure] <input type="checkbox"/> 2. remove storage (incl. under decks/ overhangs/ stairs) <input type="checkbox"/> 3. relocate combust. outdoor furniture / features <input type="checkbox"/> 4. create space between plants, and between plants and structures <input type="checkbox"/> 5. Provide 10' clearance around chimneys <input type="checkbox"/> 6. Remove vegetation & debris from <input type="checkbox"/> roofs <input type="checkbox"/> eaves <input type="checkbox"/> gutters <p>Trees/Shrubs (ea. correction may apply to trees/shrubs)</p> <ul style="list-style-type: none"> <input type="checkbox"/> 7. prune trees overhanging or in contact with structures <input type="checkbox"/> 8. remove branches within 10' of the ground (limbing) <input type="checkbox"/> 9. <input type="checkbox"/> remove dead wood <input type="checkbox"/> thin crowns <input type="checkbox"/> 10. provide separation distance between trees / shrubs <input type="checkbox"/> 11. remove understory / brush / ground fuel below trees <input type="checkbox"/> 12. thin stands of trees / shrubs <p>Create additional fuel break if required by the inspector (may range from 30' – 100')</p> <ul style="list-style-type: none"> <input type="checkbox"/> 13. cut grass/weeds (max. 18" height on steep slopes) <input type="checkbox"/> 14. strip loose tree bark to 8 feet from the ground <p><input type="checkbox"/> I Other: _____</p>

ORDER TO COMPLY: As the above conditions are contrary to law, you are hereby required to correct said conditions immediately upon receipt of this notice. A re-inspection to determine whether you have complied with this notice will be conducted after _____ days. Failure to correct the violations identified on this form will constitute an infraction of the law under City of Berkeley Ordinance No. 5499N.S. and may result in the issuance of a citation, which may require your appearance in court, and a fine of up to \$500.00 for each violation every day the violations remain uncorrected. If you have any questions regarding the inspection, please contact the inspector below at the listed telephone number. Thank you for your cooperation.

Signature (person receiving report)	Inspector (Print)	Date of Insp.	Company	Shift (A) (B) (C) (D)	Telephone (510) <input type="checkbox"/> 981- <input type="checkbox"/> 981-5585 Fire Prevention
-------------------------------------	-------------------	---------------	---------	--------------------------	---