

Department of Public Works
Engineering Division

March 19, 2024

CITY OF BERKELEY
MRP TRASH CAPTURE FY 2023
SPECIFICATION NO. 23-11556-C
ADDENDUM NO. 1

Dear Bidder:

The following amendments are hereby made to the Contract Specifications:

1. Specification Cover Sheet, Tentative Schedule, and Notice to Bidders

Bid opening date changed to 2:00 PM, Tuesday, March 26, 2024

2. Technical Provisions, Bid item No. 7, Submittals (Page C-12)

Replace second sentence of bullet point 4 with the following text: *“All CBI units shall be covered by a three (3) year minimum manufacturer’s warranty.”*

The City of Berkeley has revised questions from potential bidders regarding Specification No. 23-11556-C, MRP Trash Capture FY 2023 Project. In an effort to provide the same information to all potential respondents, the question is included below, along with a response from City staff.

1. **Question:** Will the City provide a temporary staging location for a roll-off bin to contain the extracted storm drain waste during the cleaning process?


Answer: *Per Bid Item No. 1 description, it is the Contractor's responsibility to locate a staging area.*

2. **Question:** Bid Line Item 15, Supplemental Work—What types of work might be requested that would fall into this category?

Answer: *Supplemental work, if approved, would entail work similar to the project's original scope. This could include the installation of additional trash capture devices.*

All other provisions of the contract documents shall remain the same. **Bidders shall submit a signed copy of Addendum No. 1 along with their Bidder's Proposal. Failure to do so may result in bid rejection.**

Sincerely,



Ronald A. Nevels, P.E.
City Engineer

Attachments: Revised Specification Package Cover Sheet
Revised Tentative Schedule
Noticed to Bidders – Revised Page 1
Technical Provisions, Bid item No. 7, Revised Page C-12

BIDDER'S ACKNOWLEDGEMENT:

Name of Company: _____


Address, City, State, Zip: _____

Signature: _____

Title: _____

Print Name: _____

Date: _____



CITY OF BERKELEY
DEPARTMENT OF PUBLIC WORKS
ENGINEERING DIVISION
SPECIFICATIONS

FOR
MRP TRASH CAPTURE FY 2023
SPECIFICATION NO. 23-11556-C

MARCH 2024

PRE-BID MEETING: None
BID OPENING DATE: ~~March 21, 2024~~ **March 26, 2024**

1947 CENTER STREET, 4th FLOOR, BERKELEY, CALIFORNIA 94704
(510) 981-6400

TENTATIVE SCHEDULE

(DATES SUBJECT TO CHANGE)

- | | | |
|----|---------------------------------------|-------------------------------------------------|
| 1. | Advertisement | February 28, 2024 |
| 2. | Pre-Bid Meeting | None |
| 3. | Bid Opening | March 21, 2024 March 26, 2024 |
| 4. | Pre-Award Conference | May 7, 2024 |
| 5. | Council Award | May 14, 2024 |
| 6. | Contract Documents Due | May 22, 2024 |
| 7. | Contract Award
(Notice to Proceed) | June 12, 2024 |
| 8. | Start Construction | July 5, 2024 |
| 9. | Complete Construction | September 13, 2024 |

NOTICE TO BIDDERS

1. Sealed bids will be received by the Finance Department – General Services Division in their office, **2180 Milvia Street, 3rd Floor**, Berkeley, California up to the hour of:

2:00 P.M., ~~Thursday, March 21, 2024~~ Tuesday, March 26, 2024

at which time bids will be publicly opened and read by a representative of the General Services Division for the work provided for in the plans and specifications. One (1) full set of originals and two (2) additional original signature pages (Page 9) of the bid must be submitted, on forms which were prepared for this purpose and furnished by the City. Proposals must be submitted in a sealed envelope marked **MRP TRASH CAPTURE FY 2023 SPECIFICATION NO. 23-11556-C**.

Pre-Award Conference: The apparent low bidder will be invited to a pre-award conference scheduled for 11:30 A.M., Tuesday, May 7, 2024 at 1947 Center Street, 4th Floor, Berkeley, CA.

2. Scope of Work:
The work to be performed under these specifications consists of, but is not limited to:

Installation of connector pipe screens, inlet filter devices, retractable inlet screens, construction area signs, vehicular and pedestrian traffic control, drainage structure modifications, and other related work.
3. California Contractor License Classification required:
A General Engineering
4. Location: Various locations throughout the City of Berkeley.
5. Plans and Specifications will be made available online for download, under the project's listing, at the City of Berkeley's Public Works website under Current Construction Project Bid Opportunities: <https://berkeleyca.gov/doing-business/working-city/bid-proposal-opportunities>.

Bidders are responsible for notifying Ricardo Salcedo, Associate Civil Engineer, via email at RSalcedo@BerkeleyCA.gov to be included on the Planholders List. Please include the following in the email subject header: "Spec. 23-11556-C – Request to be included in project Planholders List". In the body of the email, please state the Company Name, Address, Telephone Number, and Fax Number.

6. Compliance with SB 854: Public Works Reform: No contractor or subcontractor may be listed on a bid proposal for a public works project (submitted on or after March 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].

BID ITEM NO. 7 - CATCH BASIN INSERT (FOR CATCH BASIN THROAT LENGTH ≤ 36-INCHES)

GENERAL

The work specified in this section includes the furnishing and installation of Catch Basin Inserts (CBI) for stormwater quality treatment into existing catch basins. The CBI unit prevents trash and debris from entering the storm drain system during dry weather and moderate storm flows by directing trash and sediment into a solids basket which keeps pollutants above the permanent water level inside the catch basin.

CBI shall be installed at locations shown in the Contract Plans and at other locations identified by the Engineer.

CBI units shall be Full-Trash Capture Device as defined by the Municipal Regional Stormwater Permit Order No. R2-2022-0018 (MRP) and shall be on the list of Certified Full Trash Capture Devices approved the San Francisco Bay Regional Water Quality Control Board.

The MRP can be viewed at the following website address:

https://www.waterboards.ca.gov/sanfranciscobay/board_decisions/adopted_orders/2022/R2-2022-0018.pdf

SUBMITTALS

Prior to initiating fabrication, the Contractor shall submit hydraulic and structural calculations, shop drawings, catalog cuts, and other information required which completely describes the units to be installed under this Contract. The following information shall be included in the submittal:

1. Hydraulic/structural calculations shall be provided demonstrating that the devices are designed to allow bypass flows for a 10-year storm frequency.
2. Detailed shop drawings and descriptions of all components of the unit, showing all dimensions, materials used, connection details, assembly details, and mounting details. The shop drawings shall clearly describe the mechanical operation of the unit.
3. Installation details and instructions.
4. Warranty information, including contact information for replacement parts. ~~All CPS units shall be covered by a eight (8) year minimum manufacturer's warranty.~~ **All CBI units shall be covered by a tree (3) year minimum manufacturer's warranty.** The warranty shall cover the units against corrosion, excessive wearing of moving parts, and operational malfunction for any reason. The manufacturer shall provide, at no cost to the City, all labor, material and equipment required to repair or replace the units during the warranty period including, but not limited to, calibration and adjustment of moving parts to ensure the unit operates properly. There shall be no limit to the number of repairs or replacements required during the warranty period to